

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	3810.9 cd per klm.
(Luminaire orientation as tested.)	0.5 degrees vertical
	-0.5 degrees horizontal

Beam Spread	At 10% of Imax	42.2V x 42.6H
	At 50% of Imax	16.7V x 17.0H
	At 90% of Imax	6.6V x 6.5H

Beam Flux	Total	716.2 lumens per klm.
	To 10% of Imax	462.4 lumens per klm.
	To 50% of Imax	197.7 lumens per klm.
	To 90% of Imax	43.2 lumens per klm.

Upward LOR	0.0 %
Downward LOR	71.6 %


Luminaire Efficiency (Light Output Ratio)	71.2 %
---	--------

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 01 September 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME: 96GRF1/31524	TYPE: 96GRF1/31524	WEIGHT: 1
SPEC.:	DIM.: F 100 x 80	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 3 Circle	Shielding Angle:



DATA OF LAMP		PHOTOMETRIC DATA	
MODEL	96GRF1/31524	Imax (cd)	1029
NOMINAL POWER (W)	3	AVAILABILITY (%)	46.2
RATED VOLTAGE (V)	230	Avai. FLUX (lm)	124.7
NOMINAL FLUX (lm)	270	LOR (%)	71.2
LAMPS INSIDE	1	TOTAL FLUX (lm)	192.4
TEST VOLTAGE (V)	230	θ @50% (H,V)	17,17DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm		Φ t	Φ a
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00
90	0.00	0.00	0.00	0.00	0.01	0.01	0.02	0.03	0.03	0.03	0.03	0.02	0.01	0.01	0.00	0.00	0.00	0.00	0.21	0.00
80	0.00	0.00	0.00	0.01	0.02	0.04	0.06	0.09	0.10	0.10	0.10	0.08	0.05	0.03	0.01	0.00	0.00	0.00	0.70	0.00
70	0.00	0.00	0.01	0.03	0.06	0.10	0.14	0.17	0.20	0.21	0.20	0.17	0.12	0.06	0.03	0.01	0.00	0.00	1.51	0.00
60	0.00	0.00	0.02	0.05	0.11	0.19	0.28	0.35	0.41	0.42	0.38	0.30	0.21	0.11	0.05	0.02	0.00	0.00	2.89	0.00
50	0.00	0.00	0.03	0.08	0.19	0.33	0.49	0.74	0.94	0.95	0.72	0.47	0.30	0.16	0.07	0.02	0.00	0.00	5.48	0.00
40	0.00	0.01	0.03	0.12	0.26	0.45	0.82	1.53	2.22	2.21	1.55	0.82	0.42	0.21	0.08	0.03	0.01	0.00	10.8	0.59
30	0.00	0.01	0.04	0.14	0.31	0.58	1.40	3.36	6.28	5.78	3.07	1.40	0.57	0.25	0.10	0.03	0.01	0.00	23.3	16.0
20	0.00	0.01	0.05	0.14	0.33	0.70	1.97	6.08	20.1	17.9	5.18	1.92	0.70	0.28	0.11	0.04	0.01	0.00	55.5	49.6
10	0.00	0.01	0.05	0.14	0.32	0.71	1.97	5.80	18.0	15.6	5.10	1.91	0.72	0.29	0.11	0.04	0.01	0.00	50.8	44.9
0	0.00	0.01	0.04	0.12	0.28	0.58	1.38	3.12	5.25	5.06	2.97	1.38	0.59	0.26	0.11	0.04	0.01	0.00	21.2	13.5
-10	0.00	0.01	0.04	0.10	0.21	0.42	0.80	1.41	1.97	1.95	1.41	0.82	0.42	0.21	0.09	0.03	0.01	0.00	9.89	0.13
-20	0.00	0.00	0.03	0.08	0.15	0.27	0.44	0.64	0.79	0.81	0.67	0.48	0.30	0.17	0.08	0.03	0.00	0.00	4.93	0.00
-30	0.00	0.00	0.02	0.05	0.10	0.15	0.24	0.34	0.41	0.43	0.40	0.32	0.21	0.12	0.05	0.02	0.00	0.00	2.85	0.00
-40	0.00	0.00	0.01	0.03	0.06	0.08	0.11	0.15	0.19	0.23	0.22	0.18	0.11	0.06	0.03	0.01	0.00	0.00	1.48	0.00
-50	0.00	0.00	0.00	0.01	0.03	0.04	0.05	0.06	0.08	0.09	0.08	0.07	0.04	0.03	0.01	0.01	0.00	0.00	0.60	0.00
-60	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.02	0.01	0.01	0.00	0.00	0.00	0.00	0.17	0.00
-70	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00
-80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	-90	-80	-70	-60	-50	-40	-30	-20	HORIZONTAL (DEG)	20	30	40	50	60	70	80	90			
Φ t	0.00	0.06	0.37	1.11	2.44	4.67	10.2	23.9	57.0	51.8	22.1	10.3	4.80	2.25	0.93	0.32	0.06	0.00	192	---
Φ a	0.00	0.00	0.00	0.00	0.00	0.00	0.62	16.0	50.0	44.4	13.4	0.24	0.00	0.00	0.00	0.00	0.00	0.00	---	125

one-half-peak spread: U:7.5,D:9.3 , L:9.3,R:7.8

NEMA Beam Type: Type 3

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:01 September 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456


Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks:

ISOCANDELA DIAGRAM

NAME: 96GRF1/31524	TYPE: 96GRF1/31524	WEIGHT: 1
SPEC.:	DIM.: F 100 x 80	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 3 Circle	Shielding Angle:




C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: HIGH
 Temperature: 25.3°C
 Operators:
 Test Date: 01 September 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity: 65.0%
 Test Distance: 6.265m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM


NAME: 96GRF1/31524	TYPE: 96GRF1/31524	WEIGHT: 1
SPEC.:	DIM.: F 100 x 80	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 3 Circle	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 01 September 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

Planar Illuminance Curve




C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: HIGH
 Temperature: 25.3°C
 Operators:
 Test Date: 01 September 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity: 65.0%
 Test Distance: 6.265m [K=1.0000]
 Remarks:

AAI Figure

NAME: 96GRF1/31524	TYPE: 96GRF1/31524	WEIGHT: 1
SPEC.:	DIM.: F 100 x 80	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 3 Circle	Shielding Angle:



Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature: 25.3°C

Operators:

Test Date: 01 September 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456

Humidity: 65.0%

Test Distance: 6.265m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRF1/31524	TYPE: 96GRF1/31524	WEIGHT: 1
SPEC.:	DIM.: F 100 x 80	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 3 Circle	Shielding Angle:

Table--1

UNIT: cd

H(DEC) V(DEC)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-85	0.00	0.00	0.00	0.01	0.02	0.01	0.00	0.03	0.05	0.04	0.03	0.05	0.06	0.05	0.04	0.03	0.02	0.01	0.00
-80	0.00	0.00	0.00	0.02	0.05	0.06	0.07	0.10	0.14	0.14	0.13	0.16	0.17	0.16	0.14	0.16	0.16	0.15	0.14
-75	0.00	0.00	0.00	0.04	0.09	0.11	0.14	0.22	0.30	0.35	0.40	0.45	0.51	0.52	0.53	0.55	0.58	0.60	0.60
-70	0.00	0.00	0.02	0.07	0.13	0.20	0.30	0.44	0.57	0.70	0.78	0.90	0.98	1.04	1.08	1.17	1.28	1.41	1.52
-65	0.00	0.00	0.04	0.10	0.20	0.35	0.53	0.75	0.98	1.19	1.42	1.59	1.69	1.79	1.94	2.14	2.34	2.53	2.68
-60	0.00	0.00	0.05	0.12	0.30	0.55	0.81	1.13	1.51	1.89	2.16	2.30	2.46	2.69	3.01	3.33	3.64	3.92	4.15
-55	0.00	0.01	0.07	0.19	0.45	0.75	1.11	1.63	2.22	2.58	2.88	3.13	3.53	3.94	4.39	4.93	5.50	6.10	6.65
-50	0.00	0.01	0.08	0.27	0.60	0.97	1.51	2.29	2.92	3.41	3.88	4.38	4.99	5.65	6.56	7.89	8.90	9.74	10.5
-45	0.00	0.02	0.10	0.35	0.73	1.20	2.00	2.94	3.68	4.39	5.09	5.97	7.00	8.57	10.2	11.5	12.7	13.5	14.1
-40	0.00	0.03	0.12	0.45	0.87	1.54	2.53	3.60	4.57	5.59	6.69	8.25	10.00	11.8	13.9	15.3	16.7	17.7	18.2
-35	0.00	0.03	0.15	0.53	1.04	1.88	3.10	4.30	5.51	6.89	8.62	10.5	12.7	15.5	18.6	21.6	23.6	25.1	26.4
-30	0.00	0.04	0.18	0.60	1.20	2.24	3.65	4.97	6.50	8.27	10.5	12.9	16.6	21.8	25.7	30.5	34.9	38.4	40.1
-25	0.00	0.04	0.20	0.67	1.38	2.56	4.18	5.66	7.50	9.61	12.4	16.1	22.2	28.1	37.0	46.6	55.7	62.1	64.1
-20	0.00	0.04	0.22	0.73	1.53	2.91	4.65	6.31	8.51	11.2	14.7	19.8	27.1	37.3	51.6	70.2	89.9	104	109
-15	0.00	0.04	0.23	0.79	1.65	3.20	5.03	6.98	9.46	12.8	16.6	22.5	32.7	48.9	71.4	105	136	163	172
-10	0.00	0.05	0.24	0.83	1.74	3.44	5.36	7.50	10.1	13.9	17.9	25.3	38.6	60.2	94.9	143	216	312	334
-5	0.00	0.05	0.24	0.85	1.78	3.60	5.61	7.85	10.6	14.6	18.7	27.3	42.5	68.5	114	183	353	645	757
0	0.00	0.05	0.24	0.87	1.80	3.69	5.77	8.04	10.9	14.9	19.1	27.6	43.6	71.5	122	204	445	886	1029
5	0.00	0.05	0.23	0.86	1.78	3.55	5.77	8.09	11.1	15.0	19.0	26.8	42.2	68.1	116	194	384	736	866
10	0.00	0.05	0.23	0.85	1.74	3.33	5.64	7.98	11.0	14.9	18.6	25.0	38.4	60.0	96.9	155	246	393	452
15	0.00	0.05	0.22	0.81	1.67	3.06	5.37	7.69	10.7	14.4	17.6	22.5	32.6	48.9	73.8	111	156	191	197
20	0.00	0.04	0.21	0.76	1.57	2.74	4.89	7.28	10.0	13.5	16.2	19.8	26.3	38.3	54.0	74.8	97.8	115	118
25	0.00	0.04	0.19	0.68	1.44	2.40	4.19	6.58	9.37	12.0	14.8	17.6	21.7	28.7	39.0	50.7	62.5	72.0	74.3
30	0.00	0.04	0.17	0.59	1.30	2.15	3.46	5.52	8.15	10.6	13.1	15.6	18.0	21.8	28.3	35.0	41.2	44.6	47.1
35	0.00	0.04	0.15	0.49	1.13	1.87	2.86	4.41	6.66	8.84	10.9	12.9	15.6	17.3	20.3	24.7	28.5	31.3	32.2
40	0.00	0.03	0.12	0.40	0.93	1.60	2.35	3.48	5.19	6.88	8.48	10.3	12.0	14.1	15.8	17.0	18.7	20.0	20.9
45	0.00	0.03	0.11	0.30	0.73	1.30	1.94	2.71	3.87	5.30	6.36	7.54	8.88	9.85	11.0	11.6	12.6	13.1	13.0
50	0.00	0.02	0.10	0.21	0.52	1.01	1.52	2.07	2.84	3.99	4.88	5.47	6.25	7.02	7.67	8.20	8.67	9.02	9.25
55	0.00	0.02	0.08	0.17	0.36	0.71	1.12	1.54	2.03	2.73	3.49	4.09	4.48	4.91	5.44	5.88	6.22	6.51	6.70
60	0.00	0.01	0.07	0.11	0.22	0.43	0.75	1.07	1.38	1.75	2.17	2.66	3.12	3.47	3.73	4.05	4.45	4.72	4.87
65	0.00	0.01	0.05	0.09	0.14	0.26	0.44	0.66	0.86	1.08	1.33	1.59	1.93	2.27	2.63	2.88	3.07	3.25	3.40
70	0.00	0.01	0.04	0.06	0.08	0.15	0.24	0.38	0.50	0.64	0.79	0.95	1.11	1.33	1.59	1.84	2.07	2.15	2.17
75	0.00	0.01	0.03	0.04	0.05	0.08	0.13	0.18	0.26	0.35	0.44	0.51	0.59	0.69	0.79	0.86	0.91	0.94	0.96
80	0.00	0.00	0.02	0.01	0.02	0.04	0.07	0.08	0.09	0.12	0.17	0.22	0.25	0.31	0.36	0.38	0.39	0.40	0.41
85	0.00	0.00	0.01	0.01	0.00	0.01	0.03	0.03	0.02	0.04	0.06	0.06	0.05	0.08	0.10	0.07	0.04	0.05	0.06
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:01 September 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456

Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRF1/31524	TYPE: 96GRF1/31524	WEIGHT: 1
SPEC.:	DIM.: F 100 x 80	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 3 Circle	Shielding Angle:

Table--2

UNIT: cd

H(DEC) V(DEC)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
-85	0.03	0.06	0.05	0.04	0.05	0.06	0.05	0.03	0.04	0.05	0.03	0.01	0.02	0.03	0.01	0.00	0.00	0.00	
-80	0.16	0.17	0.17	0.16	0.17	0.18	0.16	0.13	0.13	0.13	0.11	0.08	0.07	0.06	0.03	0.01	0.01	0.01	
-75	0.64	0.66	0.64	0.61	0.59	0.56	0.51	0.46	0.39	0.32	0.24	0.17	0.14	0.11	0.06	0.01	0.01	0.01	
-70	1.57	1.59	1.52	1.42	1.27	1.12	0.99	0.87	0.76	0.63	0.48	0.34	0.24	0.16	0.09	0.04	0.02	0.00	
-65	2.75	2.76	2.69	2.52	2.24	1.96	1.67	1.43	1.22	1.00	0.77	0.57	0.39	0.24	0.13	0.06	0.02	0.00	
-60	4.38	4.58	4.83	4.57	4.07	3.35	2.67	2.17	1.81	1.50	1.16	0.83	0.57	0.35	0.17	0.08	0.02	0.00	
-55	7.35	7.67	7.61	7.22	6.56	5.51	4.28	3.41	2.68	2.24	1.68	1.14	0.77	0.47	0.24	0.10	0.03	0.00	
-50	10.9	10.9	10.6	9.94	8.99	7.73	6.44	5.14	3.93	3.09	2.41	1.57	0.99	0.60	0.31	0.12	0.04	0.00	
-45	14.3	14.1	13.5	12.6	11.5	10.1	8.28	6.74	5.33	4.13	3.04	2.11	1.22	0.74	0.38	0.14	0.05	0.00	
-40	18.1	17.8	17.0	15.7	14.1	12.3	10.2	8.21	6.54	5.00	3.60	2.70	1.56	0.87	0.45	0.17	0.06	0.00	
-35	26.2	24.7	21.8	19.4	17.2	14.6	11.9	9.71	7.66	5.85	4.14	2.99	1.88	1.01	0.52	0.20	0.07	0.00	
-30	38.9	36.8	32.2	26.7	21.4	17.8	14.0	11.2	8.75	6.64	4.75	3.27	2.19	1.13	0.59	0.23	0.07	0.00	
-25	61.6	55.3	46.5	37.3	29.0	21.7	16.6	12.5	9.89	7.35	5.25	3.54	2.43	1.28	0.65	0.25	0.08	0.00	
-20	102	87.7	68.9	52.0	38.2	27.9	19.4	14.2	10.8	8.01	5.63	3.79	2.57	1.41	0.71	0.27	0.08	0.00	
-15	161	131	99.3	70.5	49.0	33.6	22.8	16.0	11.5	8.56	5.94	3.98	2.69	1.50	0.75	0.29	0.09	0.00	
-10	274	196	133	90.5	58.9	38.5	26.6	17.9	12.3	8.89	6.10	4.11	2.78	1.55	0.77	0.29	0.09	0.00	
-5	527	283	168	106	67.2	42.6	28.5	18.6	12.9	9.03	6.12	4.16	2.83	1.57	0.79	0.30	0.09	0.00	
0	732	342	181	111	69.7	43.5	28.9	18.3	13.1	8.99	5.99	4.14	2.83	1.55	0.79	0.30	0.09	0.00	
5	642	316	167	106	67.8	42.2	27.7	18.0	12.9	8.84	5.81	4.08	2.80	1.54	0.78	0.29	0.09	0.00	
10	352	208	134	92.1	60.1	38.6	25.0	17.3	12.1	8.46	5.52	3.95	2.72	1.50	0.75	0.28	0.09	0.00	
15	173	135	103	72.8	49.6	33.0	21.7	16.4	11.4	8.01	5.17	3.77	2.58	1.42	0.72	0.26	0.09	0.00	
20	110	94.4	73.7	54.5	39.1	26.4	19.0	14.8	10.6	7.37	4.86	3.56	2.40	1.32	0.67	0.25	0.09	0.00	
25	71.7	62.9	51.4	40.0	28.7	21.1	16.6	12.9	9.85	6.43	4.54	3.32	2.17	1.20	0.62	0.23	0.08	0.00	
30	46.2	42.0	36.0	27.3	21.2	17.2	14.2	11.5	8.66	5.71	4.13	3.01	1.92	1.06	0.55	0.21	0.08	0.00	
35	31.5	28.0	22.8	19.7	16.6	14.4	12.1	10.0	7.19	5.02	3.70	2.62	1.64	0.93	0.48	0.18	0.07	0.00	
40	20.1	18.5	16.7	15.1	13.4	11.8	10.4	8.36	5.97	4.26	3.15	2.16	1.40	0.78	0.39	0.16	0.06	0.00	
45	13.6	13.4	12.7	11.7	10.7	9.72	8.30	6.71	4.87	3.48	2.55	1.77	1.15	0.64	0.30	0.14	0.06	0.00	
50	9.52	9.62	9.67	9.18	8.45	7.45	6.36	5.09	3.71	2.72	1.99	1.42	0.91	0.49	0.22	0.12	0.05	0.00	
55	6.87	6.93	6.79	6.48	6.16	5.54	4.78	3.64	2.69	2.05	1.54	1.08	0.65	0.34	0.17	0.11	0.04	0.00	
60	4.96	4.94	4.79	4.60	4.33	3.85	3.14	2.39	1.92	1.49	1.11	0.74	0.41	0.20	0.13	0.09	0.03	0.00	
65	3.43	3.39	3.26	3.04	2.72	2.30	1.86	1.54	1.22	0.95	0.69	0.43	0.23	0.14	0.10	0.07	0.03	0.00	
70	2.10	1.98	1.83	1.63	1.42	1.22	1.05	0.86	0.69	0.50	0.35	0.21	0.14	0.09	0.08	0.05	0.02	0.00	
75	0.95	0.93	0.87	0.80	0.71	0.61	0.52	0.43	0.31	0.21	0.16	0.13	0.09	0.06	0.05	0.03	0.02	0.00	
80	0.39	0.37	0.36	0.34	0.28	0.22	0.19	0.15	0.11	0.08	0.08	0.07	0.05	0.02	0.02	0.02	0.01	0.00	
85	0.07	0.07	0.08	0.08	0.06	0.04	0.05	0.05	0.03	0.01	0.02	0.02	0.01	0.00	0.01	0.01	0.01	0.00	
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:01 September 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456

Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks: